

GOVERNMENT OF MANIPUR
FIRE SERVICE DEPARTMENT



No. 5/2/MISC/2025-FS/ 548

Dated 29/05/2025.

FIRE SAFETY CERTIFICATE

Certified that the MARIA MONTESSORI SCHOOL (name of the school) located at KOIRENGEI, IMPHAL EAST DISTRICT, MANIPUR (address) comprised of PUCCA CONSTRUCTION owned/occupied by MARIA MONTESSORI SCHOOL TRUST has already been issued fire safety certificate bearing No 5/2/MISC/2024-FS/220. The premises was re-inspected by Shri W. Rona Singh, Sub-Officer of Manipur Fire Service on 29/05/2025 (date of inspection) in the presence of AKOIJAM SUPRIYA, PRINCIPAL and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. Therefore, the school is fit for occupancy of Class GROUP "B" Educational building (B-1), with effect from 29/05/2025 for a period of 1(one) year in accordance with rule and subject to compliance of the conditions.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life and property due to non-functional fire safety measures shall be at the responsibility of the management.
3. Fire-fighting training & mock drill exercise shall be organized quarterly/half yearly with intimation of fire Service Department.
4. The trained fire-fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. Water source of Fire Fighting purposes be available in the school throughout the year.
7. All exits provided in the building shall be kept free from any obstruction.
8. First Aid Kits and necessary medicines are readily available in the school.
9. Fire/Emergency Telephone numbers shall be displayed on the Notice Board.

Issue on 29/05/2025.

Signature with Seal : _____

Name

Designation

L. Nabachandra Singh
: Director,
Manipur Fire Service,
Imphal.

(L. Nabachandra Singh)
Director,
Manipur Fire Service
Imphal